

Non-automatic fire equipment should display safety signs in accordance with the Safety Signs and Signals Regulations 1996. These regulations require the fire fighting equipment to be marked with a permanent sign board in red. All fire signs comply with DIS3864 Part 1 which requires a white border on all fire signs.



FIR 001 200 x 300
FIR 002 400 x 600




FIR 003 200 x 200
FIR 004 400 x 400



FIR 005 200 x 200
FIR 006 400 x 400



FIR 007 200 x 200
FIR 008 400 x 400



FIR 009 200 x 200
FIR 010 400 x 400



FIR 011 200 x 200
FIR 012 400 x 400



MAN 013 200 x 200
MAN 014 400 x 400



FIR 015 200 x 300
FIR 016 400 x 600



FIR 017 200 x 200
FIR 018 400 x 400



FIR 019 200 x 200
FIR 020 400 x 400



FIR 021 200 x 200
FIR 022 400 x 400



FIR 023 200 x 200
FIR 024 400 x 400



FIR 025 200 x 300
FIR 026 400 x 600




FIR 027 200 x 300
FIR 028 400 x 600



FIR 029 200 x 300
FIR 030 400 x 600



FIR 031 200 x 300
FIR 032 400 x 600



FIR 033 200 x 200
FIR 034 400 x 400



FIR 035 200 x 200
FIR 036 400 x 400



FIR 037 200 x 200
FIR 038 400 x 400



FIR 039 200 x 200
FIR 040 400 x 400



CO²
FIR 041 200 x 300
FIR 042 400 x 600



FIR 043 200 x 200
FIR 044 400 x 400



FIR 045 200 x 200
FIR 046 400 x 400



Dry powder
FIR 047 200 x 300
FIR 048 400 x 600



FIR 049 200 x 200
FIR 050 400 x 400



FIR 051 200 x 200
FIR 052 400 x 400



EMERGENCY
FIR 053 200 x 200
FIR 054 400 x 400



EMERGENCY
DIAL 999
FIRE - POLICE
AMBULANCE
FIR 055 200 x 200
FIR 056 400 x 400



FIR 057 300 x 100
FIR 058 600 x 200



FIR 059 300 x 100
FIR 060 600 x 200